



A SAFE SCHOOLS TRANSPORTATION STUDY

## Cypress Ridge Elementary School

# Priority Project #1

## School Accessibility Improvements

### Findings:

- ✓ Only one handicap parking space provided, and it has no accessibility to the curb (existing accessible ramp is fenced off)
- ✓ No curb ramps or accessible access point provided at either of the parent drop-off / pick-up loops

### Recommendations:

- ✓ Make changes to bring site up to ADA compliance including addition of handicap spaces in both parking areas, addition of curb ramps, restriping crosswalk with FDOT ladder style markings, etc.



Handicap parking at front of school



Crosswalk at front of school



Crosswalk at front of school