

Priority Project #1

Student Parking Lot Accessibility Improvements



ADA Ramp not adjacent to Handicap Spaces in Student Lot



ADA Ramp not adjacent to Handicap Spaces in Student Lot

Findings:

- ✓ Student parking lot has 2 handicap parking spaces but no ramp is provided to sidewalk at these spaces; however, there is a ramp a few spaces down the same row of parking

Recommendations:

- ✓ Restripe portion of closest student parking row to school to locate handicap spaces on either side of existing curb ramp; this change would be less costly than constructing a new curb ramp at the existing handicap spaces