

### Findings:

- ✓ A student in a wheelchair was observed to go all the way around the parking spaces, out the exit and down Yellow Jacket Way and 15<sup>th</sup> St in the road until reaching an accessible ramp to the existing sidewalk
- ✓ Students observed walking directly from front of school through parking lot and north on US 27

### Recommendations:

- ✓ Construct new sidewalk connections from the front of the school and car loop to the existing sidewalks at Yellow Jacket Way / 15<sup>th</sup> St and the US 27 signal
- ✓ Install ADA ramps with detectable warning mats and crosswalks

