

**H&B**  
**CONSULTING ENGINEERS, INC.**

October 7, 2015

Mr. Ken Comia  
City of Groveland  
156 S. Lake Avenue  
Groveland, FL 34736

Re: Lake Minneola Landings Water Main Extension Utility Plan  
Application #2015-67  
Response to 1<sup>st</sup> Review Comments from September 2<sup>nd</sup>, 2015 Letter

Mr. Comia:

We have reviewed the comments provided for the above referenced project and have responses as follows:

**Engineering**

***Sheet 3***

1. **Changes in direction or elevation of pressure pipe shall be accomplished using fittings.**
  - o Please see General Notes added to Sheet 3.
2. **Services connection to the water mains shall not be located under pavement (i.3. Services to lots 53 and 54).**
  - o Please see General Notes added to Sheet 3.

***Sheet 4***

3. **Include a sequence of construction for connecting to the existing water main while maintaining service and accommodating the pressure in the existing plan.**
  - o Please see Sequence of Construction, Tie In Notes added to Sheet 4.

***Hydraulic Analysis***

4. **No comment.**

If have any questions or require additional information, please advise.

Sincerely,



Thomas F. Wille, A.E.T.  
H&B Consulting Engineers, Inc.

Cc: Ms. Leslie Hurst, FCI  
Mr. Britt Barnes, FCI

14-417.kc.0100715