## Request Details Report

| Request Number<br>MA3-7509-R       |   | Associated Work Order |                                  |                   |             | <b>Observed Date/Time</b> 6/18/10 9:49:A |      |
|------------------------------------|---|-----------------------|----------------------------------|-------------------|-------------|--|------|
| Citizen Inf<br>Name                | ormation                                  | David                 | Day                              |                   | Phone       | (352) 759-3360                           | Ext. |
| F                                  | 24605<br>Alligator Rd (97880)<br>Astor FL |                       | Alternate Phone<br>Email Address |                   |             |  |      |
| ganization<br>Requestor<br>Contact |   |                       |                                  |                   |             |  |      |
| Issue and Location Activity        |   |                       |                                  | lssu<br>Map       | e<br>Page   | Asphalt, other <b>Section</b>            |      |
| Address N                          | lumber                                    |                       |                                  |                   |             |  |      |
| Route Allig                        | ator Rd (97                               | 88O)                  |                                  |                   |             |  |      |
| Intersect F                        | Route Rive                                | r Rd (                | 9787)                            |                   |             |  |      |
| Details Citizen says t             | that the road is                          | s sinking             | . He believ                      | ves that the pipe | e under the | road is leaking.                         |      |
| History                            |   |                       |                                  |                   |             |  |      |
| 6/18/2010                          | Request has                               | s been p              | rinted and                       | given to the Sup  | ervisor.    | Wall, Treeva                             |      |
| 6/21/2010                          | Contract pip                              | e replac              | ement req                        | uested.           |             | Lee, Steven                              |      |
| Re                                 | solution                                  |                       |                                  |                   |             |  |      |
| Request Resp                       |   |                       |                                  |                   |             |  |      |
|                                    |   |                       |                                  | -                 |             |  |      |

## PIPE REPLACEMENT REQUEST

Road Name:

Alligator Rd

Road #: 9788O Segment #: 01

Address:

Under Alligator where it intersects with River & Hyacinth

Section: 19

Township: 15 Range: 28


Culvert under roadway is deteriorating and roadway is settling/sinking. Will need to replace 10 ft long x 20 ft wide section of roadway.

Pipe required: 40 ft of 18 inch pipe.

Cover: 12 inches from surface to top of pipe.

Bottom of culvert to ground level: 30 inches.

Inlet/Outlet Ends: Concrete mitered ends.





## MAINTENANCE AREA 3 ASSET

Lake County Road Operations
May 2008 Edition

