

PIPE REPLACEMENT REQUEST

Road Name: River Rd Road #: 9787 Segment #: 01
Address: At intersection of River Rd & Hyacinth Rd
Section: 30 Township: 15 Range: 28

Culvert under roadway is rotten. Edge of road is sinking.

Pipe required: 38 ft of 24 inch (existing is cmp)

Cover: 14 inches from surface to top of pipe.

Bottom of culvert to ground level: 38 inches.

Inlet/Outlet Ends: Inlet is Concrete mitered end with a makeshift headwall. Recommend a headwall.
Outlet is concrete mitered end.

Asphalt to be replaced: 10 ft by 20 ft.

S.V.

Request Details Report

Request Number
MA3-11507-R

Associated Work Order

Observed Date/Time
11/18/13 2:23:P

Citizen Information

Name	Phone	Ext.
Address	Alternate Phone	
	Email Address	

Organization

Requestor Lake County Public Works

Contact Lee, Steve

Issue and Location

Activity	Issue	Drainage
	Map Page	SEC TWN RNG

Address Number

Route River Rd (9787)

Intersect Route Hyacinth Rd (9787C)

Details

Supervisor noticed rotten pipe.

Notes

History

Resolution _____

Request Response Date 11/18/2013 _____

Date _____

Time Arrived _____

Time Departed _____

