

PIPE REPLACEMENT REQUEST

REQ #: MA3-12678-R

ROAD NAME: Ermine Rd

Address: 24008

Road # 9787J Seg # 1

Sec 25

Twon 15

Rng 27

Description of Problem: Rotten pipe.

Description of Existing Pipe: 15" x 30' cmp

Pipe Required: 15" x 30'

Cover: 6 in

Bottom of culvert to ground level: 21 in

Inlet/Outlet Ends: concrete mitered

Asphalt to be cut out and replaced: concrete - 13 ft x 16 ft

S.L.

Sod Required: watever is disturbed

Request Details Report

Request Number
MA3-12678-R

Associated Work Order

Observed Date/Time
10/20/14 9:26:A

Citizen Information

Name

Phone

Ext.

Address

Alternate Phone

Email Address

Organization

Requestor Lake County Public Works

Contact Sherk, Adam

Issue and Location

Activity

Issue

Shoulder

MSC Field Inspection

Map Page

SEC TWN RNG

Address Number

Route Ermine Rd (9787J)

Intersect Route

Details

Adam got a call Sat. that someone ran off the road somewhere along Ermine Rd. and tore up the shoulder as well as a mitered end.

Notes

For work done by Maintenance Area, see MA3-21094-WO.

History

11/13/2014 Contract pipe replacement requested.

Lee, Steven

Resolution _____

Request Response Date 10/20/2014

Date _____

Time Arrived _____

Time Departed _____

We are working on a new Interactive Map that will replace this site. We encourage you to test the new site and leave us feedback to help shape its future. [Beta test the new Interactive Map.](#)

[Click here to change page title](#)



#	Alt Key	Owner	Parcel Address	Owner Address	Tools
1	3801757	CLARK KAREN AND JIM MASTERSON	24008 ERMINE RD ASTOR FL 32102	24008 ERMINE RD ASTOR, FL 32102	Zoom In