

PIPE REPLACEMENT REQUEST

REQ #: MA3-13517-R

ROAD NAME: Bobcat Rd

Address: 24144

Road # 9787N Seg # 01

Sec 25

Twon 15

Rng 27

Description of Problem: Rotten pipe. Driveway is beginning to collapse on East side.

Description of Existing Pipe: 15" x 30' CMP

Pipe Required: 15" x 30'

Cover: 8"

Bottom of culvert to ground level: 23"

Inlet/Outlet Ends: Concrete Mitered

Asphalt to be cut out and replaced: 10' x 30'

Sod Required: Sod disturbed areas.

S.L.

Request Details Report

Request Number
MA3-13517-R

Associated Work Order

Observed Date/Time
7/13/15 10:20:A

Citizen Information

Name Katrina Blount

Phone (352) 551-3043 Ext.

Address 24144

Alternate Phone

Bobcat Rd (9787N)

Email Address

Astor FL

Organization

Requestor

Contact

Issue and Location

Activity

Issue

Drainage

Map Page

SEC TWN RNG

Address Number 24144

Route Bobcat Rd (9787N)

Intersect Route

Details

Citizen reports that the culvert is collapsed and the driveway apron is washed out. Her car bottoms out when coming in and out. A lot of sand has washed out of her yard ... she says it looks like a sinkhole.

Notes

History

7/13/2015 Contract pipe replacement requested.

Lee, Steven

Resolution _____

Request Response Date 07/13/2015

Date _____

Time Arrived _____

Time Departed _____

LAKE COUNTY CONNECT INTERACTIVE MAP

All - 1606349 Search

