

PIPE REPLACEMENT REQUEST

REQ #: MA3-13530-R

ROAD NAME: Armadillo Rd

Address: 55625 Fern Rd (pipe is on Armadillo)

Road # 97870 Seg # 01

Sec 25

Twon 15

Rng 27

Description of Problem: Rotten pipe.

Description of Existing Pipe: 33' x 15" CMP

Pipe Required: 33' x 15"

Cover: 6"

Bottom of cuivert to ground level: 21"

Inlet/Outlet Ends: Concrete mitered.

Asphalt to be cut out and replaced: 14'6" wide

Sod Required: disturbed areas

CA

Request Details Report

Request Number
MA3-13530-R

Associated Work Order

Observed Date/Time
7/15/15 12:59:P

Citizen Information

Name

Phone

Ext.

Address

Alternate Phone

Email Address

Organization

Requestor Lake County Public Works

Contact Hicks, Chris

Issue and Location

Activity

Issue

Drainage

Map Page

SEC

TWN

RNG

25

15

27

Address Number

Route Armadillo Rd (97870)

Intersect Route

Details

Rotten pipe. Pipe is on Armadillo. Address is 55625 Fern Rd.

Notes

History

Resolution _____

Request Response Date 07/15/2015

Date _____

Time Arrived _____

Time Departed _____





LAKE COUNTY CONNECT INTERACTIVE MAP

All 1746221 Search

