


Merrell's Grade-All, Inc.



RECEIVED

JAN 24 2017

LAKE COUNTY
ROAD OPERATIONS

INVOICE

450 Ketch Road- Saint Cloud, Florida 34771
Phone (407) 892-4700 Fax (407) 892-0808

INVOICE #004
DATE: JANUARY 18, 2017

TO:
Lake County Public Works
Road Operations
12901 County Landfill Road
P.O. Box 7800
Tavares, FL 32778-7800

For:
Contract No. 16-0022
Purchase Order No.: 20161333
Right-of-Way Shoulder Rehabilitation

DESCRIPTION	Item	RATE	AMOUNT
Morningside Drive (4568)	LS	\$8,820.00	\$8,820.00
<i>AB 1-24-17</i> TOTAL:			\$8,820.00

Remit to: **Merrell's Grade-All, Inc.** 450 Ketch Road; Saint Cloud, FL 34771
Total due upon receipt. Overdue accounts subject to a service charge of 1% per month.

JK 1/31/2017

Thank you for your business!

OK TO PAY - FY 16/17

*BP
1/31*

PO#: 20161333
Acct#: 1120.5053200.830467
Goods Recd: 1 1 3 1 1 7
KJC 01-24-17
1/31/17

16-0022 Shoulder Rehabilitation

Route:	footage:	seg. #	ok date
Cherry Lake Road	16,200 Lf	2-1829-01 thru. 05	
Coralwood Lane	2,300 LF	2-1926-01	
Country Road	4,420 LF	3-7798A-01	ok 12/1/2016
CR 44A (6286)	12,430 LF	3-6286-19 thru. 21	ok 11/28/2016
CR 44A (6678 & 7077)	26,308 LF	3-6678-01 & 3-7077-01	ok 10/20/2016
East Crooked Lake Dr.	4,000 LF	3-5069-14	cancelled 11/30/2016
Griffin Avenue	2,306 LF	1-7807-15	ok 1/18/2017
Griffin Road (CR 44C)	4,520 LF	1-4908-02 thru. 04	ok 1/3/2017
Morningside Drive	2,100 LF	3-4568-11	ok 1/3/2017
Oak Avenue	1,000 LF	3-7798-01	ok 12/1/2016
Old Eustis Road	3,343 LF	3-4672-08	cancelled 11/30/2016
Woodlea Road	14,282 LF	1-3840-01 thru. 05	ok 1/3/2017
Wolfbranch Road	7,286 LF	3-4583-29	

AB 1-24-17

**Attachment B
Pricing Schedule**

Merrell's Grade-All, Inc.				
Days to Complete	Price Option 1 (no discount)	Price Option 2 (awarded multiple)	Price Option 3 (awarded all)	
Cherry Lake Road (1829)	\$ 77,940.00	\$ 77,760.00	\$ 68,040.00	
Coralwood Lane (1926)	\$ 11,730.00	\$ 11,500.00	\$ 9,660.00	
Country Road (7798A)	\$ 6,000.00	\$ 5,900.00	\$ 4,200.00	
County Road 44A (6678/7077)	\$ 110,493.60	\$ 110,493.60	\$ 110,493.60	
County Road 44A (6286)	\$ 58,421.00	\$ 57,178.00	\$ 52,206.00	
East Crooked Lake Drive (5069)	\$ 24,000.00	\$ 22,000.00	\$ 16,800.00	
Griffin Avenue (7807)	\$ 12,683.00	\$ 12,452.40	\$ 9,685.20	
Griffin Road (4908)	\$ 20,792.00	\$ 20,692.00	\$ 18,984.00	
Morningside Drive (4568)	\$ 12,600.00	\$ 12,390.00	\$ 8,820.00	
Oak Avenue (7798)	\$ 17,640.00	\$ 16,758.00	\$ 12,348.00	
Old Eustis Road (4672)	\$ 18,386.50	\$ 16,715.00	\$ 14,040.60	
Woodlea Road (3840)	\$ 65,697.20	\$ 62,840.80	\$ 59,948.40	
TOTAL:	\$ 436,383.30	\$ 426,679.80	\$ 385,225.80	

The County reserves the right to make award(s) on a lowest price basis to the responsive and responsible vendor(s) who submits the lowest price by individual item, group of items, all or none, or a combination thereof with one or more vendor(s).

Engineering & Materials Testing

Reply to:
Leesburg

December 28, 2016

Merrells Grade-All, Inc.
450 Ketch Rd.
Saint Cloud, Florida 34771
(407) 342-1320

Attention: Mr. John Palmer


Subject: Materials Testing Services
Lake County Shoulder Repair Project
Morningside Dr. ←
Mount Dora, Lake County, Florida
CTL Project 1684119.100

Dear Mr. Palmer:

As requested, Central Testing Laboratory, Inc. (CTL) has been providing materials testing services for the above mentioned project. Field Density test results are presented on the attached sheets. The testing was performed in accordance with the referenced AASHTO/ASTM standards.

CTL appreciates the opportunity to provide our services on this project. Should you have any questions concerning this report, please do not hesitate to contact our Leesburg office.

Sincerely,
CENTRAL TESTING LABORATORY, INC.


Theodore J. Strouse, P.E.
President
Florida Reg. No. 48220
11/27/17

TJS/tmb
Enclosure:

5400 S. Florida Avenue
Inverness, FL 34450
(352) 726-6447

130 Satellite Ct.
Leesburg, FL 34748
(352) 787-1268

Sumter County
(352) 793-3110

Marion County
(352) 622-1186



TEST LOCATION	TEST INTERVAL	PERCENT OPTIMUM MOISTURE	LAB DENSITY lbs/ft ³	ROADWAY		PERCENT FIELD MOISTURE	FIELD DENSITY lbs/ft ³	PERCENT DENSITY
				WIDTH	DEPTH			
Tests performed on 12/22/16 in accordance with ASTM D 6938 using AASHTO T-180 (Modified Proctor) Morningside Dr. Mount Dora								
Right Shoulder - From South End Head North 98% Required								
Station 5+00 Final Grade	6"	11.0	118.0	N/A	N/A	12.5	116.7	99
Station 10+00 Final Grade	6"	11.0	118.0	N/A	N/A	11.8	112.1	95
Station 15+00 Final Grade	6"	11.0	118.0	N/A	N/A	12.5	115.0	97
Station 20+00 Final Grade	6"	11.0	118.0	N/A	N/A	12.6	114.2	97
Station 25+00 Final Grade	6"	11.0	118.0	N/A	N/A	11.9	113.7	96
Tests performed on 12/22/16 in accordance with ASTM D 6938 using AASHTO T-180 (Modified Proctor) Morningside Dr. Mount Dora								
Right Shoulder - From South End Head North 98% Required								
Station 30+00 Final Grade	6"	11.0	118.0	N/A	N/A	12.0	117.5	100
Station 35+00 Final Grade	6"	11.0	118.0	N/A	N/A	12.2	113.8	96
Station 40+00 Final Grade	6"	11.0	118.0	N/A	N/A	12.0	118.4	100
Station 45+00 Final Grade	6"	11.0	118.0	N/A	N/A	11.4	115.3	98
Station 50+00 Final Grade	6"	11.0	118.0	N/A	N/A	11.8	114.4	97