

HNTB

June 17, 2008

Ms. Ruth E. Grady, E.I.
Department of Water Resources
St. Johns River Water Management District
975 Keller Road
Altamonte Springs, FL 32714

Re: Hartwood Marsh Road
US 27 to 1500 feet east of Hancock Road
Application Number 40-069-114354-1
Response to Request for Additional Information

114354-1
RECEIVED IN
ALTAMONTE SPRINGS

JUN 20 2008

REGULATORY
INFORMATION MGT.

Dear Ms. Grady:

Please find enclosed the following revised documents to the South Hancock Road Environmental Resource Permit Application.

- Three (3) copies of the Construction Plans
- Three (3) copies of the Response to Request for Additional Information

We offer the following responses to your comments.

Comment 1: Please address and/or provide the following with respect to *Sheet Nos. 92, 92A, 95, 96, 97, 98 and 100* of the set of revised construction plans submitted:

- a. The *Pond 2* bottom elevation delineated on *Sheet No. 92* and utilized in the water quality and quantity calculations (e.i., 104.0 feet) does not appear to be consistent with that (105.0 feet) delineated in the *Pond 2 Cross Sections* located *Sheet Nos. 95, 96, 97, and 98*. Please clarify, and revise where appropriate, for accuracy with the post development condition.

- b. Amend the Sheet No. 92A control structure specifications to include the upstream and downstream invert elevations for the proposed control structure S-128 outfall pipe.
- c. The response to Item No. 10 of the District's January 3, 2008, RAI letter states that the previously proposed *Pond 2* overflow connection into the existing Regency Hills surface water management system (District Permit No. 40-069-82413-2 "*was eliminated from the project.*") This, however, appears to be inconsistent with the notation delineated on *Sheet No. 100*. Accordingly, please clarify and revise where appropriate, for accuracy with the post-development condition.

Submit any revised plans and calculations. [40C-4.301(1)(a)(b)(c)(e)(i); 40C-42.025(6); 40C-42.026(1), F.A.C.]

Response:

- a. *The Pond 2 cross sections (Sheets 95, 96, 97, and 98) have been updated to show the correct bottom elevation of 104.0 feet.*
- b. *Sheet 92A had been amended to show the upstream and downstream invert elevations for S-128.*
- c. *Sheet 100 has been amended to reflect the response to Item 10. of the District's January 3, 2008, RAI letter.*

If you have any questions or need further information, please do not hesitate to contact our office.

Sincerely,

HNTB Corporation



Melinda S. Fischl, E.I.
Project Designer

cc: Tom McCann, P.E. (Lake County Public Works)



Letter of Transmittal

HNTB Job # 41561-1
 VIA US Mail
 Date 6-18-08

To Ms. Ruth Grady, EI **Regarding** Hartwood Marsh Road
Department of Water Resources Environmental Resource Permit
St Johns River Water Management District Application Number 40-069-114354-1
975 Keller Road Request For Additional Information
Altamonte Springs, Fl 32714-1618

We are forwarding to you

Estimates Plans Prints
 Reports Shop Drawings Samples
 Change Order Disk Copy of Letter
 Book Other

# of Copies	Drawing #	Last Dated	Code	Description
3				Response to RAI
3				Construction Plans

These are transmitted

For approval As requested Copies for distribution
 For your use Resubmit For Review & comment
 Return Copies for review No exception taken
 Corrected prints Submit Amend and resubmit
 Make corrections noted

Please note

By Melinda S. Fischl, EI
 Copy to Tom McCann, PE (Lake County)
file

114354-1
 RECEIVED IN
 ALTAMONTE SPRINGS
 JUN 20 2008
 REGULAR MAIL
 INFORMATION ONLY