## Utility Conflict Matrix

Project Owner:	Lake County
Project No. :	L3609
<b>Project Description:</b>	Jalarmy Roundabout

 $\textbf{Utility Conflict Matrix Developed/Revised By:} \ \underline{ \ \textit{Benjamin Kelk} }$ 

Date: 7/2/2025

Reviewed	By:

Highway or Route: Jalarmy Road and Lake Minneola Shores

Note: refer to subsheet for utility conflict cost analysis.

Utility Owner and/or Contact Name	Conflict ID	Drawing or Sheet No.	Utility Type	Size and/or Material	Utility Conflict Description	Start Station	Start Offset	End Station	End Offset	Utility Investigation Level Needed	Test Hole	Recommended Action or Resolution	Estimated Resolution Date	Resolution Statu
	1	13	Electric	Wood	Power Pole and guy anchors in proposed future trail	100+12.17	32.82' LT							
	2	13	Communications		Utility Riser in proposed future trail	100+59.58	32.54' LT							
	3	13	Electric	Wood	Power Pole and guy anchors in proposed roadway	102+24.21	7.79' LT							
	4	13	Unknown		Proposed 18" RCP crosses Unknown line	103+58.54	44.24' RT							
	5	13	Communications		Proposed 18" RCP crosses BT line	103+63.21	37.51' RT							
	6	13	Communications		Proposed 18" RCP crosses BT line	103+64.70	35.31' RT							
	7	15	Electric	Wood	Power Pole and guy anchors in proposed roadway	500+50.33	34.72' RT							
	8	15	Communications		Proposed 18" RCP crosses BT line	501+22.06	22.15' RT							
	9	15	Unknown		Proposed 18" RCP crosses Unknown line	501+34.01	14.40' RT							
	10	15	Unknown		Proposed 18" RCP crosses Unknown line	501+48.30	5.92' RT							
	11	15	Unknown		Proposed 18" RCP crosses Unknown line	501+67.45	4.24' LT							
	12	15	Unknown		Proposed 18" RCP crosses Unknown line	502+03.71	6.45' LT							
	13	15	Unknown		Proposed 18" RCP crosses Unknown line	502+05.07	4.08' LT							
	14	15	Communications			502+06.04	2.39' LT							
	15	15	Unknown		Proposed 18" RCP crosses Unknown line	502+45.22	19.97' LT							
Lake Apopka Natural Gas District	16	15	Gas	PVC	Proposed future trail crosses 4"	502+58.14	33.36' LT	502+67.67	13.19' LT					
	17	15	Communications		Pull box in path of proposed future	502+62.88	35.40' LT							
	18	15	Communications		Box in path of proposed future trail	502+63.15	22.55' LT							
2	19	15	Communications		Box in path of proposed future trail	502+64.38	30.89' LT							
	20	15	Electric	Wood	Power Pole and guy anchors in proposed future trail	502+67.15	30.88' LT							
	21	15	Communications		Proposed 18" RCP crosses Unknown line	503+04.12	19.76' LT							
Lake Apopka Natural Gas District	22	15	Gas	PVC	Proposed 18" RCP and Curb Inlet cross 4" gas main	503+39.57	17.94' LT	503+47.41	18.20' LT					
	23	15	Water		Proposed Curb Inlet in path of water main	503+42.37	15.81' LT	503+47.52	15.96' LT					