

Rodriguez, Jeremy

From: Scott, Jimmy
Sent: Wednesday, February 5, 2020 4:31 PM
To: Lynch, Seth; Rodriguez, Jeremy
Subject: RE: Bishops Gate Sanitary Sewer FM CR 48. Permit #9253

I agree, it should be fine.
Thanks.



TERRY SCOTT
Construction Inspection Supervisor

PUBLIC WORKS DEPARTMENT
Engineering Division

A P.O. Box 7800 Tavares, FL 32778
P 352-253-9024 | **F** 352-253-6016
E jscott@lakecountyfl.gov | **W** www.lakecountyfl.gov

*NOTE: Florida has a very broad public records law.
Your email communications may be subject to public disclosure.*

From: Lynch, Seth
Sent: Wednesday, February 5, 2020 3:47 PM
To: Rodriguez, Jeremy <jdrodriguez@lakecountyfl.gov>; Scott, Jimmy <JScott@lakecountyfl.gov>
Subject: RE: Bishops Gate Sanitary Sewer FM CR 48. Permit #9253

I am okay with the change.

Thanks,
Seth



SETH LYNCH
Development Engineer

PUBLIC WORKS
Engineering Division, Development Section

A P.O. BOX 7800, 323 N. Sinclair Ave, Tavares, FL, 32778
P 352-253-9052
E slynch@lakecountyfl.gov | **W** www.lakecountyfl.gov

*NOTE: Florida has a very broad public records law.
Your email communications may be subject to public disclosure.*

From: Rodriguez, Jeremy
Sent: Wednesday, February 05, 2020 2:16 PM
To: Scott, Jimmy <JScott@lakecountyfl.gov>; Lynch, Seth <SLynch@lakecountyfl.gov>
Subject: RE: Bishops Gate Sanitary Sewer FM CR 48. Permit #9253

All,

Please see below/attached. Mr. Clutts is needing a response; please take a look at this and let me know.

Thank you,



JEREMY D. RODRIGUEZ

Public Works Permitting Technician

PUBLIC WORKS DEPARTMENT
Engineering Division

A 323 N. Sinclair Ave. Tavares, FL 32778

P 352-253-6019 | **F** 352-253-6016

E jdrodriguez@lakecountyfl.gov | **W** www.lakecountyfl.gov

NOTE: Florida has a very broad public records law.

Your email communications may be subject to public disclosure.

From: Rodriguez, Jeremy

Sent: Tuesday, February 4, 2020 4:08 PM

To: Scott, Jimmy <JScott@lakecountyfl.gov>; Lynch, Seth <SLynch@lakecountyfl.gov>

Subject: FW: Bishops Gate Sanitary Sewer FM CR 48. Permit #9253

Terry, Seth,

Please see below/attached. The permit can be found at the following link:

[ftp://ftp.co.lake.fl.us/Public_Works/Road%20Operations/Permitting%20Files/Right%20of%20Way%20Permits/9253\(1\).pdf](ftp://ftp.co.lake.fl.us/Public_Works/Road%20Operations/Permitting%20Files/Right%20of%20Way%20Permits/9253(1).pdf)

Thank you,



JEREMY D. RODRIGUEZ

Public Works Permitting Technician

PUBLIC WORKS DEPARTMENT
Engineering Division

A 323 N. Sinclair Ave. Tavares, FL 32778

P 352-253-6019 | **F** 352-253-6016

E jdrodriguez@lakecountyfl.gov | **W** www.lakecountyfl.gov

NOTE: Florida has a very broad public records law.

Your email communications may be subject to public disclosure.

From: David Clutts [<mailto:dclutts@civilengsolutions.com>]

Sent: Tuesday, February 4, 2020 3:50 PM

To: Rodriguez, Jeremy <jdrodriguez@lakecountyfl.gov>

Subject: Bishops Gate Sanitary Sewer FM CR 48. Permit #9253

CAUTION: This email originated from outside of your organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Jeremy,

Per the voice message I left earlier today, I have attached a redlined plan sheet showing the area where the contractor needs to shift the force-main on CR-48 away from the field marked Telecommunication line. This is a fairly minor adjustment and will include this on our as-built drawings and it will be depicted on the drillers logs.

I am requesting feed-back that the County acknowledges this change in alignment is okay.

Thanks in advance and I look forward to a response.

-David

David Clutts, P.E., Owner/President
Civil Engineering Solutions, Inc.
322 North Rockingham Ave.
Tavares, Florida 32778
Land (352) 742-5011
Cell (352) 552-4670
Fax (352) 742-5044