

ADDENDUM #1

Lake Woodward Stormwater Pump Station
Project No. 2022-04, Bid No. 22-553

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. **Receipt of this addendum shall be acknowledged by the bidder by signing and dating the appropriate line on page W-4 of the bid proposal.** Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.

The bid opening date remains July 14, 2022. All requests for information must be submitted by July 5, 2022.

A non-mandatory pre-bid meeting for the referenced project was held at 11:00 a.m. on June 16, 2022, via a telephone conference. The following were in attendance:

Name	Company	Phone Number	Email Address
Dianne Woods	Carr & Collier, Inc.	352-764-3700	dwoods@carrandcollier.com
Zachary Fields	Prime Construction Group	407-856-8180	zfields@primeconstructiongroup.com
Basil Marone	CFE		
	Intercounty Engineering		
Jeff Earhart	Lake County Public Works	(352) 253-6009	jeearhart@lakecountyfl.gov
Dan Flannery	Lake County Public Works	(352) 253-6021	dflannery@lakecountyfl.gov
Nick Mcray	Lake County Public Works	(352) 253-9080	nmcray@lakecountyfl.gov
Terry Scott	Lake County Public Works	(352) 253-9024	jscott@lakecountyfl.gov
Blake Livingston	Lake County Public Works	(352) 253-9023	blivingston@lakecountyfl.gov
Deb Marchese	Lake County Public Works	(353) 253-6007	dmarchese@lakecountyfl.gov

The Lake Woodward Stormwater Pump Station project consists of replacing an existing stormwater pump station and associated stormwater force mains to convey water from Lake Woodward to Lake Saunders. The engineer's estimate is \$532,450.00. This project is funded through a Joint Participation Agreement (JPA) with the Florida Department of Transportation. Contractor awarded this project shall be a FDOT prequalified contractor.

Work performed under this contract shall be based on a lump sum bid. Quantities, if shown in the construction plans, are estimated for bidding purposes only and shall be verified by the contractor.

Pay special attention to all notes shown in the construction plans.

Contractor shall video the project limits prior to beginning construction. The video shall be on a thumb drive and provided to Lake County before construction begins. Detail

should be given to all existing fence lines, driveways, hedge lines, etc., to document existing conditions prior to construction.

Bid to sod all disturbed areas matching all existing grass types. Contractor shall be responsible for watering all sod until there is established growth.

All utilities shown in the construction plans to be relocated shall be the responsibility of the utility provider to relocate. Contractor is responsible for the coordination of all utility relocation.

Contractor shall provide two complete sets of red-lined record drawings upon completion of the project. One submitted set is to be on a flash drive while the other in paper format. The record drawings must show all additions, omissions, and adjustments made throughout construction of the project. The record drawings are to be signed and sealed by a professional engineer or surveyor, licensed to do business in the State of Florida. The record drawings are to be a complete set of construction plans, but only sheets that display changes must be signed and sealed by the engineer or surveyor.

Contractor shall add a line item to the bid tabulation sheet in Division W of the bidding document for any items that may be required but not shown on the tabulation sheet.

No oral interpretations will be made to any bidder as to the meaning of the Specifications, or any other Contract Documents. Every request for such an interpretation must be in writing, and shall be received by the Office of Procurement Services not less than ten (10) calendar days prior to the date set for opening of bids. Every interpretation made to a bidder will be made by an addendum to the Contract Documents, which, when issued, will be sent as promptly as is practicable to all persons to whom the Specifications have been issued by the County. All such addenda shall become part of the Contract Documents. No substitution of any kind or riders of any nature to the bids will be considered except by the above-described method. For purposes of this Contract the term "Interpretations" shall include the approval of product substitution. All requests for interpretation shall be submitted to Amy Munday, Senior Contracting Officer, at amunday@lakecountyfl.gov and copied to Deb Marchese, Construction Program Coordinator, at dmarchese@lakecountyfl.gov.

Each Contractor shall visit the site of the proposed work and fully acquaint themselves with conditions relating to construction and labor so that they may fully understand the facilities, difficulties and restrictions attending the execution of work under the contract.

Contractor shall be responsible for quality control testing on this project. Contractor may add "Quality Control testing" as a line item in the Bid Tabulation.

On sheet C2.01 of the construction plans, the proposed water line is shown to be installed by open trench, under and within the drip line of an oak tree. Contractor shall directional drill under the tree causing little to no impact to the oak tree.

Questions Asked Via Email

Q1: What are the approximate length, sizes and type of the pipes to be installed on the project?

A1: As shown in the Construction plans, there are two types and sizes of water line associated with this project. The proposed 584' of Directional Drill pipe shown is a 14 inch, SDR 11. The proposed 485' open trench pipe is 12 inch PVC, conforming to AWWA C-900, DR 18, or PE 3408.

Q2: Are there any portions of the project that will need to be Bored?

A2: Yes, approximately 584 feet of Directional Drill

Q3: Are the crossings to be Jack & Bored or Directionally Bored?

A3: As shown in the construction plans, all pipe under the roadway shall be directional drill.

Q4: What are the approximate lengths and size of the portions to be bored?

A4: See answer to question number 1

Q5: Do you have any further details you wish to provide?

A5: No

Questions Asked at the Pre-Bid Meeting

Q6: What is the length of contract on this project?

A6: Contractor shall determine the number of days required to complete the project.



Deborah Marchese, Construction Program Coordinator



Date