

## ADDENDUM #2

CR 48 Guardrail Replacement  
Project No. 2023-05, Bid No. 23-543

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. **Receipt of this addendum shall be acknowledged by the bidder by signing and dating the appropriate line on page W-4 of the bid proposal.** Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.

The bid opening date remains May 25, 2023. The date for requests for information has expired.

### **Questions Asked at Via Email**

**Q1:** We are bidding as a subcontractor. Does Lake County release or share a list of plan holders to which we can offer our services?

**A1:** Lake County offers free access to the plans for this project and does not have a way to track what contractors download the plans, so we do not have a plan holders list.

**Q2:** The bid sheet has a line item for new Vinyl coated chain link fence. However, there is no installation of any fencing shown on the construction plans or details. There is a note on page C-17 in two locations that, states "relocated Vinyl Coated Chain Link Fence". It doesn't state who is relocating it. Also, the one on-site is not Vinyl coated.

Are we to include a line item for fence removal?

Is the existing fence just being removed and relocated? Is it being done by Contractor?

Are we to plan to install New black vinyl coated chain link?

**A2:** Contractor shall remove the existing fence. Contractor shall furnish and install the vinyl coated fence as shown on sheets C-17 & C-18. Contractor shall utilize blank spaces in the bid tabulation to add any items necessary to perform this work.

  
\_\_\_\_\_  
Deborah Marchese, Construction Program Coordinator

5-17-23  
Date