




Office of Building Services

315 West Main St., Tavares, FL 32778 · PO Box 7800 Phone
(352)343-9653 · Website www.lakecountyfl.gov



Florida Residential Fuel Gas Code, 7th Edition

2017-2020 Significant Changes (Fuel Gas Code)

G2406.2 (303.3) Prohibited Locations for Appliances

A gas-fired clothes dryer is now allowed to be installed in a bathroom or toilet room where a permanent opening communicates with other permitted spaces.

G2411.2 (310.2) Electrical Bonding of CSST

The existing provisions for electrical bonding apply to CSST without the arc-resistant jacket or coating and a new section addresses electrical continuity and bonding of arc-resistant CSST.

G2411.3 (310.3) Arc-resistant CSST

New Section added.

G2414.4.2 (403.4.2), G2414.10.1 (403.10.1) Schedule 10 Steel Gas Piping

Schedule 10 steel pipe can now be used for fuel-gas piping with limitations on fitting connections.

G2415.11 (404.11) Protection Against Corrosion

G2420.5.1 (409.5.1) Shutoff Valve Location.

Shutoff valves serving movable appliances are considered as meeting the requirements for access.

G2420.6 New Section

Support for shutoff valves in tubing systems. Rigid support separate from the tubing to prevent damage at the valve connection is now required.

G2447.2 (623.2)

Commercial cooking appliances are now permitted in dwelling units when installed in accordance with an engineered design and the manufacturer's instructions.